

Certified Validation Report Water Audit Level 1 Validation Document

Audit Information:

Water Supplier Name: Lincoln Avenue Water Company

PWS ID: 1910063

System Type: Potable

Audit Period: Calendar 2020

Utility Representation: Ben Bowen

Validation Date: 9/10/2021

Contact Time: 11:45 AM

Sufficient Supporting Documents Provided: Yes

Validation Findings & Confirmation Statement:

Key Audit Metrics:

Data Validity Score: 64

Data Validity Band (Level): Level III (51-70)

ILI: 0.92

Real Loss: 18.63 (gal/conn/day)

Apparent Loss: 8.00 (gal/conn/day)

Non-revenue water as percent of cost of operating system: 2.7%

Certification Statement by Validator:

This water loss audit report has been Level 1 validated per the requirements of California Code of Regulations Title 23, Division 2, Chapter 7 and the California Water Code Section 10608.34.

All recommendations on volume derivation and Data Validity Grades were incorporated into the water audit. ☒

Validator Information:

Water Audit Validator: Christopher Hamilton

Qualifications: Water Audit Validator Certificate issued by CA-NV AWWA



Certified Validation Report Water Audit Level 1 Validation Document

Water Supplier Name:

Water Supplier ID Number:

Water Audit Period:

Water Audit & Water Loss Improvement Steps:

Steps taken in preceding year to increase data validity, reduce real loss and apparent loss as informed by the annual validated water audit:

<<This information to be completed by Utility before DWR submittal.>>

- 1) Continued progression of AMI meter upgrade process.
- 2) GIS system has moved into first phase of implementation for field operational use.

Certification Statement by Utility Executive:

This water loss audit report meets the requirements of California Code of Regulations Title 23, Division 2, Chapter 7 and the California Water Code Section 10608.34 and has been prepared in accordance with the method adopted by the American Water Works Association, as contained in their manual, *Water Audit and Loss Control Programs, Manual M36, Fourth Edition* and in the Free Water Audit Software version 5.

Jennifer Betancourt Torres

Executive Name (Print)

General Manager

Executive Position

[Signature]

Signature

9/13/21

Date